QLifeLab
مختبر جودة الحياة
Quality Life Laboratory

ilac-MRA

PJLA
Testing
Accreditation#90958

TEST REPORT

REPORT DETAILS:-

Accreditation No:	**90958**	**Client details:**	
Report/Job No:	24/03/5925(01)	Attention:	-
Report Dated:	28/03/2024	Company:	Integrated Indian School
Sample Collected by:	Client	Address:	Jleeb Al-Shuyoukh, Kuwait.
Sample Procedure:	APHA 9060: 2017, 23rd Ed.	Contact No:	+965- 24315963
Sample Appearance:	Sample collected in sterile container.	Email Address:	integratedindianschoolkwt@gmail.com

Sampling Details

Sample Name:	Drinking Water/ Filter	Physical Appearance:	No odor and no impurities were detected.
Sample Category:	Water	Sample Conditions:	Ambient
Sample Date & Time:	24/03/2023	Sample Received Date /Time:	24/03/2024 & 12.45pm
Sample Batch No:	-	Analysis Start Date:	24/03/2024
Sample Production Date:	-	Results Reported Date:	28/03/2024
Sample Expiry Date:	-	Sample Pick up Temperature:	23°C
Sample Location:	Corridor, Integrated Indian School, Jleeb Al-Shuyoukh	Routine/Adhoc/Retested:	-

1.Chemical Test

Sr. No.	Testing Parameters	Results	Unit	STD Limits	Uncertainty	Remarks	Method used
1.	pH	6.79	-	6.5-8.5	-	Acceptable	APHA 4500 H B:2017,23rd edition
2.	TDS	2.84	mg/L	500	-	Acceptable	APHA 2540B:2017,23rd edition

2.Microbiological Test

Sr. No.	Testing Parameters	Results	Unit	STD Limits	Uncertainty	Remarks	Method used
1.	*Total plate count*	1	cfu/ml	500	-	Acceptable	APHA 9215B:2017,23rd edition
2.	*Total coliforms*	<1	cfu/100ml	Zero(0) Tolerance	-	Acceptable	APHA 9222B:2017,23rd edition
3.	*Pseudomonas aeruginosa*	<1	cfu/100ml	Zero(0) Tolerance	-	Acceptable	ISO 16266:2006
4.	*E.coli*	<1	cfu/100ml	Zero(0) Tolerance	-	Acceptable	USEPA 1603:2014

Remarks:

- **All the microbiological and chemical parameters are within the acceptable limits as per USEPA and KEPA Standard.**
- **<1 indicates that the parameters were not detected in the test conducted on the sample provided, the value indicate is notional as per the regulation related to the reporting of test value, prescribed in the applicable test methods.**
- **This test report relates only to the samples tested in the Laboratory.**
- **QLL shall not accept any liability for any decision that may be made based on this test results.**

Analyzed By:Lab Technician	**Soumya Rinsmon**	
Reviewed By:Lab In-charge	**Jenita A. Ponsekar**	
Approved By:Lab Manager	**Sudhakar Karuppiah**	

Ritu Mathur

.....End of Report.....

Ms. Ritu Mathur
Principal
Integrated Indian School
Jleeb Al Shuyoukh Kuwait

QLifeLab مختبر جودة الحياة Quality Life Laboratory
صندوق بريد: ٧٦٦٠٠ السرة - ٧٦٠٨ - الفروانية - الضجيج - قسيمة ٦٧ - الوحة رقم ٢٥ مكتب
P.O.Box: 76600 Al Sura, 45708 kuwait - Al Farwaniya, Al Dajeej, P lot 67, Al Waha Mall, Office 25
+965 24348731 +965 22281523 lab@qualitylifelab.com
www.qualitylifelab.com